

Courts Building Energy Audit
April 24, 2008
Executive Summary

The Courts Building, built in 2001, has an energy usage of \$2.78 per Sq. Ft.. This is considerably high compared to other buildings in Fluvanna County and does not compare well with other buildings of its type nationwide. The construction of the courthouse used state of the art technology. The uses of the building and its design do not allow for a large reduction of energy usage. However some reductions up to 5% are possible.

Primarily; some adjustments of the air intake, temperature setbacks and boilers will allow for some savings. Adding occupancy sensors to lights in seldom used areas will help also. Instructing staff to turn off lights in unused spaces and other user interactions would yield some savings. (See recommendations) There is a possibility that emergency generators could be used to reduce peak energy costs, this is being explored. A professional technical audit team has conducted a preliminary examination of the building and we are awaiting their recommendations.

Submitted by: Curtis Putnam

Recommendations from Energy Audit of Courts Building April 24, 2008

- Use blinds to reduce night heat loss in winter and to reduce heat gain during the summer.
- Increase summer thermostat setting in courtrooms when unoccupied.
- Reset outside air to enable use of economizer function
- Test Boiler combustion efficiency
- Turn off one boiler for the summer
- Remove scale deposits from boiler and water side surfaces.
- Use economizer cycle in winter to provide cooling.
- Post instructions for staff to turn out lights in unused spaces and when leaving area.
- Install occupancy sensors in some offices.
- Find a way to reduce electrical demand.

2. ANNUAL ELECTRIC USE AND COST
Include Electrical Demand, if applicable

Building	Address	Year of Record From	Year of Record To						
Counts	72 main street	2012	2018						
Account Number 8895892548	Meter Number 15079056	Utility Dominion	Building size (sqft) 24,828						
Maximum KW Demand W/O charge	Minimum Power Factor W/O charge								
1	2	3	4	5	6	7	8	9	10
Meter Read Date From	Meter Read Date To	KWh* Used	KWh/gross sq. ft. **	Annual (EUI) BTU/sqft (000)	Energy Cost	KW-KVA Demand	Fixed Service Cost	P.F. * and Demand Cost****	Total Cost
2-21	3-21	27900				75		101687	214221
3-21	04-23	33600				81		119790	263741
4-23	5-18	29700				97		90750	222702
5-18	6-22	49500				105		129070	348996
6-22	7-23	49200				114		146601	346951
7-23	8-22	48300				12600		225341	327305
8-22	9-20	47400				10800		1448	346605
9-20	10-02	48600				9300		135354	287352
10-22	11-21	36000				9000		126331	254043
11-21	12-19	30000				9000		146937	333120
12-19	1-25	39000				9000		122640	251481
1-25	2-21	30600				9000			35334
TOTAL		409800	24,828	18.09	64581				35334

Comments:

Conversion: 3413 BTU/KWh

*KW – Kilowatts, KVA – Kilo-Volt-ampere, KWH – Kilowatt hour, P.F. – Power Factor

**Total annual kWh divided by the building's gross sq. ft.

***If demand and/or power factor are metered and billed, energy cost here.

3. ANNUAL NON-ELECTRIC ENERGY USE AND COST

Photo copy this form for additional fuel types

Building	Address	Year of Record From	Year of Record To	Utility	Annual (EUI) Btu/sq.ft.	Cost \$
Account Number	Meter Number	Fuel Type	Specify Units	MMBTU	Conversion Factor	Fuel consumption
Billing Period From	To	Fuel consumption	MMBTU	Conversion Factor	Fuel consumption	Annual (EUI) Btu/sq.ft.
Courts	72 Main St	2-07	2-08	Tiger fuel		
944/3390		#2 Fuel oil	Gallons			
24,828						
2-9	1190					2598.12
3-23	990					2317.36
6-22	2994.5					7013.12
10-15	2971.8					7301.71
12-18	2180.5					6120.66
1-20	1840.2					4972.22
2-19	1185.8					3408.87
TOTAL				1796	72066	33729

***Conversion Factors**

Natural Gas	100,000 Btu/therm
Natural Gas (LP bottled gas)	1,030 Btu/cubic feet
Liquified Petroleum	95475 Btu/gallon
Kerosene	134,000 Btu/gallon
Distillate Fuel Oil	138,690 Btu/gallon
Residual Fuel Oil	149,690 Btu/gallon
Coal	24.5 million Btu per Standard short ton
Wood	8,680 Btu/pound
Steam	970 Btu/pound
Other	Consult standard Engineering Reference Manual

Comments:

$\$ 2.78 / \text{sq. ft.}$
 $\text{EUI} = 90256 \text{ Btu/sq.ft.}$

